



CERTIFICATE

System evaluation and conformance with standards

Certificate-No.: KC/505031304-1/10/2026

Certificate owner: Portus Data Centers Muenchen GmbH
Marsstraße 5
85551 Kirchheim bei München

Test/Certification symbol:



Location: Portus Data Center MUC1
Marsstraße 5
85551 Kirchheim bei München

Examined parameters: Availability Class AC4
Protection Class PC1 – PC4

Examined in accordance with:

DIN EN 50600 – Data centre facilities and infrastructures

- DIN EN 50600-1: 2019-08 – General concepts
- DIN EN-50600-2-1: 2021-09 – Building construction
- DIN EN-50600-2-2: 2019-08 – Power distribution
- DIN EN-50600-2-3: 2019-08 – Environmental control
- DIN EN-50600-2-4: 2023-09 – Telecommunications cabling infrastructure
- DIN EN-50600-2-5: 2021-09 – Security systems
- DIN EN-50600-3-1: 2016-08 – Management and operational information

Examination result:

The Data centre described above was voluntarily tested and found to meet the standard defined requirements of the aforementioned standards. This Certificate is based on audit report “505.031.304 Auditbericht Re-Zertifizierung EN50600 Portus MUC1”, dated May 12, 2026.

This certificate is valid until May 20, 2029.

Munich, June 16, 2026


Gerhard Klein
Technical Certifier
Energy and Systems




Marten Becker
Certification Body
Energy and Systems

